Code: 164734-07

CLD	CLD E			× NO		IP66	IK10
RG0	•)))	EM S.A.	-0050 11111 EM-EC	EM EC	NO/	CE	₩.




Thema is a new lamp, which boasts the best technical features of the other waterproof fixtures in the Disano range, but with substantial differences that make it stand out from our major competitors.



		GENERAL INFORMATION
Article	970 - Thema - LED	ı
Code	164734-07	
		DIMENSIONS AND WEIGHT
Length (mm)	1260 mm	
Width (mm)	120 mm	
Height (mm)	102 mm	
Weight (Kg)	2.3 kg	
		ELECTRICAL CHARACTERISTICS AND CONTROLS
Voltage type	AC	
Min Voltage (V)	220 V	
Max Voltage (V)	240 V	
Min Frequency (Hz)	50 Hz	
Max Frequency (Hz)	60 Hz	
Frequency (Hz)	50 Hz	
Wiring name	CLD-E	
Power factor	≥0.95	
Insulation class	Class I	
Controllability	None	



Code: 164734-07



36 H	
12:01:03	


Lighting source	LED	
CRI	≥80	
Luminous flux (output) (lm)	4328 lm	
Power absorption (total) (W)	37 W	
ССТ	4000 K	
Luminous efficacy (lm/W)	117 lm/W	
Low Flicker	luminaire with very low flicker: evenly distributed light for greater visual safety.	
Colour consistency	SDCM3	
LED flux maintenance	80000 hr, L 80, B 10	
	MECHANICAL CHARACTERISTICS	
Impact resistance rating (IK)	IK10	
IP	66	
Ambient temperature - min	5 °C	



Please contact the Consulting and Design Centre for any technical information. The reported luminous flux is the flux emitted by the light source with a tolerance of ± 10% compared to the indicated value. The total wattage absorbed by the system will not exceed 10% of the reported value. Technical lighting data may be subject to changes and improvements due to the fast evolution of the technology. Saturday, December 21, 2024

PHOTOMETRIC DATA

Code: 164734-07



After sales warranty	5 yr
	-0050 WARRANTY
Upon request	GEAR - narrow beam, subcode -22 - continuous row with connector on both ends, subcode -0072 - radar sensor for ON-OFF watertight fixtures, subcode -19 - with CLD-EC wiring for centrally powered emergency lighting, subcode
Laboratory Tests Energy Label	class material that self-extinguishes in 25 seconds. - passes the Glow Wire Test at 850 °C. C
	- the UL 94 Standard is considered a reference for rating the ignition characteristics of plastic materials. The watertight fixtures are made of V2
Reference standards	EN60598-1. With degree of protection according to EN60529. The lighting fixture meets all IFS and BRC requirements, and the regulation of the HACCP Directive regarding lighting systems installed in food processing plants.
Markings and tests	CE, ENEC
Photobiological safety class	RG0
	STANDARDS AND COMPLIANCE
Emergency operation time	1h
Type of emergency	S.A.
	EMERGENCY LIGHTING
	ATTENTION ! Do not install on surfaces subject to strong vibrations, outdoors on hanging cables, or on walls under metallic grates, or on poles, and in any case, never expose the fixture to direct sunlight. Check the compatibility between the material constituting the product and the space where it will be installed. We recommend the use of fixtures made of steel with direct exposure to sunlight.
Equipment	 sealing gasket in eco-friendly, anti-aging expanded polyurethane foam ceiling mounting brackets and suspension hook in stainless steel quick connector clamp and safety screws in stainless steel
Colour	Grey
Diffuser	injection-moulded in polycarbonate with internal grooves for greater light control, self-extinguishing V2, UV-stabilised, smooth outer finish to enable easy cleaning for maximum light efficiency.
Optics	galvanised steel pre-painted in oven with white polyester resin, UV- stabilised. Fastened to the body with a quick coupling by means of a device machined directly on the body.
	UV-stabilised, with high mechanical strength thanks to the structure reinforced by internal ribs.

DOWNLOAD

MOUNTS

AssemblyInstructions hydro - thema 12-23.pdf DESIGNS

BIM 970 Thema - LED - 20200214 .zip

TechnicalDrawing 970k.dxf



ISUNU 🜗
illuminazione

Please contact the Consulting and Design Centre for any technical information. The reported luminous flux is the flux emitted by the light source with a tolerance of ± 10% compared to the indicated value. The total wattage absorbed by the system will not exceed 10% of the reported value. Technical lighting data may be subject to changes and improvements due to the fast evolution of the technology. Saturday, December 21, 2024

MATERIALS AND COLOURS

Code: 164734-07



975 Anti-impact grid



Please contact the Consulting and Design Centre for any technical information. The reported luminous flux is the flux emitted by the light source with a tolerance of ± 10% compared to the indicated value. The total wattage absorbed by the system will not exceed 10% of the reported value. Technical lighting data may be subject to changes and improvements due to the fast evolution of the technology. Saturday, December 21, 2024